

Thornton Township HS District 205
Thornridge HS, Thornwood HS, Thornton HS, Admin Building
Drinking Fountains

RESAMPLING INFO

| Equip. Number | Building | Floor | Location | Notes (Discoloration, smells, etc) | *Hygieneering Sample ID | Location Description sink direction (N,S,E,W) Left, or right; landmark, etc | Date | Copper | | Lead | Lead MCL (ppb) | Resample Date | Resampled copper result (ppb) | Resampled Lead Result (ppb) |
|---------------|------------|-------|-------------------|---------------------------------------|----------------------------|---|-----------|------------|-----------|--------------|-------------------|------------------|-------------------------------------|--------------------------------|
| | | | | | | | | Result ppb | MCL (ppb) | Result (ppb) | | | | |
| KS1 | Admin | 1 | Break Room | X | KS1 | Lounge | 9/23/2017 | ND | 1300 | ND | 15 | | | |
| BFP | Thornridge | 1 | Boiler Room | X | BFP | Left | 7/22/2017 | ND | 1300 | 14 | 15 | | | |
| DF1 | Thornridge | 1 | Commons Area | X | DF1 | Across from 302 | 7/23/2017 | ND | 1300 | ND | 15 | | | |
| DF10 | Thornridge | 1 | C97 | X | DF10 | C-Hall | 7/24/2017 | ND | 1300 | ND | 15 | | | |
| DF11 | Thornridge | 1 | C-Hall | X | DF11 | Door 3 | 7/25/2017 | 502 | 1300 | ND | 15 | | | |
| DF12 | Thornridge | 2 | C211 | X | DF12 | C-Hall | 7/26/2017 | 737 | 1300 | ND | 15 | | | |
| DF13 | Thornridge | 2 | D and C Hallway | X | DF13 | Intersection Of Hallways | 7/27/2017 | ND | 1300 | ND | 15 | | | |
| DF14 | Thornridge | 2 | D213A | X | DF14 | D-Hall | 7/28/2017 | 152 | 1300 | ND | 15 | | | |
| DF15 | Thornridge | 2 | C220 | X | DF15 | C-Hall | 7/29/2017 | ND | 1300 | ND | 15 | | | |
| DF16 | Thornridge | 2 | B201 | X | DF16 | B-Hall | 7/30/2017 | ND | 1300 | 18.1 | 15 | 9/1/17 | ND | ND |
| DF17 | Thornridge | 2 | B209 | X | DF17 | B-Hall | 7/31/2017 | 331 | 1300 | ND | 15 | | | |
| DF18 | Thornridge | 2 | A204 | X | DF18 | A-HALL | 8/1/2017 | 154 | 1300 | ND | 15 | | | |
| DF19 | Thornridge | 2 | A202 | X | DF19 | A-HALL | 8/2/2017 | 498 | 1300 | ND | 15 | | | |
| DF2 | Thornridge | 1 | Main Gym | X | DF2 | Left Fountain | 8/3/2017 | ND | 1300 | ND | 15 | | | |
| DF20 | Thornridge | 1 | Left Auditorium | X | DF20 | A-HALL | 8/4/2017 | ND | 1300 | ND | 15 | | | |
| DF21 | Thornridge | 1 | Right Auditorium | X | DF21 | A-HALL | 8/5/2017 | 794 | 1300 | ND | 15 | | | |
| DF23 | Thornridge | 1 | D100 | X | DF23 | Daycare classroom, sink | 8/6/2017 | ND | 1300 | ND | 15 | | | |
| DF24 | Thornridge | 1 | B/G Bathroom | X | DF24 | Right of Nurse, D- Hall | 8/7/2017 | 224 | 1300 | ND | 15 | | | |
| DF25 | Thornridge | 1 | Cafeteria | X | DF25 | Left Fountain | 8/8/2017 | 273 | 1300 | ND | 15 | | | |
| DF26 | Thornridge | 1 | Faculty Lounge | X | DF26 | Bottle Filler | 8/9/2017 | ND | 1300 | ND | 15 | | | |
| DF27 | Thornridge | 1 | Kitchen Entrance | X | DF27 | D-Hall, Right Of Entrance | 8/10/2017 | 194 | 1300 | ND | 15 | | | |
| DF28 | Thornridge | 1 | Concessions | X | DF28 | Spigot | 8/11/2017 | ND | 1300 | ND | 15 | | | |
| DF3 | Thornridge | 1 | F-2 Gym | Low Flow | DF3 | Right Fountain | 8/12/2017 | 243 | 1300 | 27.5 | 15 | 9/1/17 | ND | ND |
| DF4 | Thornridge | 1 | F-1 Gym | X | DF4 | Left | 8/13/2017 | ND | 1300 | ND | 15 | | | |
| DF5 | Thornridge | 1 | E-Hallway | X | DF5 | Left | 8/14/2017 | ND | 1300 | ND | 15 | | | |
| DF6 | Thornridge | 1 | 107A | X | DF6 | B-Hall | 8/15/2017 | ND | 1300 | ND | 15 | | | |
| DF7 | Thornridge | 1 | B107 | X | DF7 | B-Hall | 8/16/2017 | ND | 1300 | ND | 15 | | | |
| DF8 | Thornridge | 1 | B112 | X | DF8 | B-Hall | 8/17/2017 | ND | 1300 | ND | 15 | | | |
| DF9 | Thornridge | 1 | Main Office | X | DF9 | Infront of Main office | 8/18/2017 | 216 | 1300 | ND | 15 | | | |
| DG22 | Thornridge | 1 | Door 4 | X | DG22 | D-Hall | 8/19/2017 | ND | 1300 | ND | 15 | | | |
| DF1 | Thornton | 1 | Room 196 | X | DF1 | | 8/20/2017 | 640 | 1300 | ND | 15 | | | |
| DF10 | Thornton | 2 | Room 211 | X | DF10 | | 8/21/2017 | ND | 1300 | ND | 15 | | | |
| DF11 | Thornton | 1 | Room 108 | X | DF11 | | 8/22/2017 | ND | 1300 | ND | 15 | | | |
| DF12 | Thornton | 1 | Room 106 | X | DF12 | | 8/23/2017 | ND | 1300 | ND | 15 | | | |
| DF13 | Thornton | 1 | Across Auditorium | X | DF13 | Left Drinking Fountain | 8/24/2017 | ND | 1300 | ND | 15 | | | |
| DF14 | Thornton | 1 | Room 109 | X | DF14 | | 8/25/2017 | 284 | 1300 | ND | 15 | | | |
| DF15 | Thornton | 1 | T102 | X | DF15 | | 8/26/2017 | ND | 1300 | ND | 15 | | | |
| DF16 | Thornton | 1 | T106 | X | DF16 | | 8/27/2017 | 189 | 1300 | ND | 15 | | | |
| DF17 | Thornton | 2 | T206 | X | DF17 | Right Drinking Fountain | 8/28/2017 | 287 | 1300 | ND | 15 | | | |
| DF18 | Thornton | 1 | T202 | X | DF18 | | 8/29/2017 | 762 | 1300 | ND | 15 | | | |
| DF19 | Thornton | 1 | Stairway 4 & 6 | X | DF19 | Main Gym | 8/30/2017 | 275 | 1300 | ND | 15 | | | |
| DF2 | Thornton | 1 | Room 169A | Yellow | DF2 | | 8/31/2017 | ND | 1300 | ND | 15 | | | |

| | | | | | | | | | | |
|------|-----------|-----------------------|----------|------|---------------------------|------------|------|------|------|----|
| DF20 | Thornton | 1 Stairway 4 | X | DF20 | Main Gym | 9/1/2017 | ND | 1300 | ND | 15 |
| DF21 | Thornton | 1 Outside Field | X | DF21 | Field | 9/2/2017 | 130 | 1300 | ND | 15 |
| DF22 | Thornton | 1 Field House | X | DF22 | Left Side of Fountain | 9/3/2017 | ND | 1300 | ND | 15 |
| DF23 | Thornton | 1 Field House | X | DF23 | | 9/4/2017 | ND | 1300 | ND | 15 |
| DF24 | Thornton | 1 Girls Locker Room | X | DF24 | | 9/5/2017 | ND | 1300 | ND | 15 |
| DF25 | Thornton | 1 Room 103 | X | DF25 | Daycare | 9/6/2017 | ND | 1300 | ND | 15 |
| DF26 | Thornton | X Concessions | X | DF26 | Right Drinking Fountain | 9/7/2017 | 269 | 1300 | ND | 15 |
| DF27 | Thornton | 1 Vocational Building | Low Flow | DF27 | | 9/8/2017 | 632 | 1300 | ND | 15 |
| DF28 | Thornton | 1 Grounds Building | X | DF28 | Wall Spigot | 9/9/2017 | 231 | 1300 | ND | 15 |
| DF29 | Thornton | X Baseball Field | X | DF29 | | 9/10/2017 | 146 | 1300 | ND | 15 |
| DF3 | Thornton | 1 Room 137 | X | DF3 | | 9/11/2017 | ND | 1300 | ND | 15 |
| DF4 | Thornton | 1 Room 163 | X | DF4 | | 9/12/2017 | ND | 1300 | ND | 15 |
| DF5 | Thornton | 2 Room 271 | Yellow | DF5 | | 9/13/2017 | ND | 1300 | ND | 15 |
| DF6 | Thornton | 3 Room 391 | X | DF6 | | 9/14/2017 | ND | 1300 | ND | 15 |
| DF7 | Thornton | 3 Room 362 | X | DF7 | | 9/15/2017 | ND | 1300 | ND | 15 |
| DF8 | Thornton | 3 Room 370 | X | DF8 | | 9/16/2017 | ND | 1300 | ND | 15 |
| DF9 | Thornton | 2 Room 229 | Low Flow | DF9 | | 9/17/2017 | ND | 1300 | ND | 15 |
| BFP | Thornwood | 1 Boiler Room | X | BFP | Left | 9/18/2017 | ND | 1300 | ND | 15 |
| DF1 | Thornwood | 1 1110 | X | DF1 | Bottle Filler | 9/19/2017 | 114 | 1300 | ND | 15 |
| DF10 | Thornwood | 1 1613 | X | DF10 | Bottle Filler | 9/20/2017 | 243 | 1300 | ND | 15 |
| DF11 | Thornwood | 1 1334 | X | DF11 | North Fountain | 9/21/2017 | 193 | 1300 | ND | 15 |
| DF12 | Thornwood | 1 1336 | X | DF12 | South Fountain | 9/22/2017 | 373 | 1300 | ND | 15 |
| DF13 | Thornwood | 1 Pool Deck | X | DF13 | Pool 1 Fountain | 9/24/2017 | ND | 1300 | 13.3 | 15 |
| DF14 | Thornwood | 1 North Gym | X | DF14 | West Fountain | 9/25/2017 | 112 | 1300 | 5.69 | 15 |
| DF15 | Thornwood | 1 North Gym | X | DF15 | East Fountain | 9/26/2017 | 177 | 1300 | 7.82 | 15 |
| DF16 | Thornwood | 1 South Fieldhouse | X | DF16 | South Fountain | 9/27/2017 | ND | 1300 | ND | 15 |
| DF17 | Thornwood | 1 South Fieldhouse | X | DF17 | North Fountain | 9/28/2017 | ND | 1300 | ND | 15 |
| DF18 | Thornwood | LL Girls Locker Room | X | DF18 | Left Fountain | 9/29/2017 | 643 | 1300 | ND | 15 |
| DF19 | Thornwood | 1 1930 | X | DF19 | x | 9/30/2017 | ND | 1300 | ND | 15 |
| DF2 | Thornwood | 1 1112/1003 | X | DF2 | x | 10/1/2017 | ND | 1300 | ND | 15 |
| DF20 | Thornwood | 1 1940 | X | DF20 | x | 10/2/2017 | ND | 1300 | ND | 15 |
| DF21 | Thornwood | 1 1654 | X | DF21 | x | 10/3/2017 | 197 | 1300 | ND | 15 |
| DF22 | Thornwood | 1 1642 | X | DF22 | Mens/Womens | 10/4/2017 | 210 | 1300 | 6.53 | 15 |
| DF23 | Thornwood | 2 2642 | X | DF23 | x | 10/5/2017 | 158 | 1300 | ND | 15 |
| DF24 | Thornwood | 2 2635 | X | DF24 | x | 10/6/2017 | 125 | 1300 | ND | 15 |
| DF25 | Thornwood | 2 2654 | X | DF25 | x | 10/7/2017 | 160 | 1300 | ND | 15 |
| DF26 | Thornwood | 2 2940 | X | DF26 | Bottle Filler | 10/8/2017 | 2060 | 1300 | ND | 15 |
| DF27 | Thornwood | 2 2255 | X | DF27 | D-Hall, Right Of Entrance | 10/9/2017 | 273 | 1300 | ND | 15 |
| DF28 | Thornwood | 2 2222 | X | DF28 | Left Fountain | 10/10/2017 | 284 | 1300 | ND | 15 |
| DF29 | Thornwood | 2 2236 | X | DF29 | x | 10/11/2017 | 447 | 1300 | ND | 15 |
| DF3 | Thornwood | 1 1007 | X | DF3 | Outside Mens/Womens | 10/12/2017 | 221 | 1300 | ND | 15 |
| DF30 | Thornwood | 2 2216 | X | DF30 | x | 10/13/2017 | 195 | 1300 | ND | 15 |
| DF31 | Thornwood | 2 2535 | X | DF31 | x | 10/14/2017 | 403 | 1300 | ND | 15 |
| DF32 | Thornwood | 2 2542 | X | DF32 | Left Fountain | 10/15/2017 | 429 | 1300 | ND | 15 |
| DF33 | Thornwood | 2 2755 | X | DF33 | Right Fountain | 10/16/2017 | 269 | 1300 | ND | 15 |
| DF34 | Thornwood | 1 Grounds Building | X | DF34 | Spigot | 10/17/2017 | 146 | 1300 | ND | 15 |
| DF4 | Thornwood | 1 1210 | X | DF4 | x | 10/18/2017 | 256 | 1300 | ND | 15 |
| DF5 | Thornwood | 1 1220 | X | DF5 | x | 10/19/2017 | 343 | 1300 | ND | 15 |
| DF6 | Thornwood | 1 1535 | X | DF6 | x | 10/20/2017 | 306 | 1300 | 5.09 | 15 |
| DF7 | Thornwood | 1 1620 Fountain Off | | DF7 | Closet Sink | 10/21/2017 | ND | 1300 | ND | 15 |
| DF8 | Thornwood | 1 1759 | X | DF8 | Left Fountain | 10/22/2017 | 296 | 1300 | ND | 15 |
| DF9 | Thornwood | 1 1612 | X | DF9 | x | 10/23/2017 | 175 | 1300 | ND | 15 |